

through (i), and § 76.10–15, shall be complied with insofar as is reasonable and practicable. In addition, vessels on an international voyage shall comply with the requirements of § 76.10–5(b).

(5) Vessels on an international voyage shall comply with the requirements of § 76.10–3.

(6) Firehose nozzles and low-velocity spray applicators must meet the requirements of §§ 76.10–10(j), 76.10–10(k), and 76.10–10(l).

(b) [Reserved]

[CGFR 65–50, 30 FR 16940, Dec. 30, 1965, as amended by CGFR 67–87, 32 FR 19181, Dec. 20, 1967; CGD 76–086, 44 FR 2392, Jan. 11, 1979; CGD 95–027, 61 FR 26004, May 23, 1996; USCG–2000–7790, 65 FR 58461, Sept. 29, 2000]

Subpart 76.13—Steam Smothering Systems

§ 76.13–1 Application.

Steam smothering systems are not permitted on vessels contracted for on or after January 1, 1962. Previously approved installations may be retained as long as they are maintained in good condition to the satisfaction of the Officer in Charge, Marine Inspection.

[CGD 95–027, 61 FR 26004, May 23, 1996]

§ 76.13–90 Installations contracted for prior to January 1, 1962.

(a) Installations contracted for prior to July 1, 1935, shall meet the following requirements:

(1) Existing arrangements, materials, and facilities previously approved will be considered satisfactory so long as they meet the minimum requirements of this paragraph and they are maintained in good condition to the satisfaction of the Officer in Charge, Marine Inspection. Minor repairs and alterations may be made to the same standard as the original installation.

(2) The main pipes and their branches to the cargo compartments and similar spaces shall be not less than 1½-inch pipe size and shall emanate from not more than two stations in easily accessible locations. If located on the open deck, the distribution manifolds shall be suitably protected by an enclosing cabinet or casing which shall be marked as required by § 78.47–17 of this subchapter. Each branch line shall

have a valve at the manifold which shall be marked as required by § 78.47–15 of this subchapter.

(3) Branches to paint lockers and similar small spaces may be taken from the nearest stream supply line and shall be not less than ¾-inch pipe size. The valve shall be marked as required by § 78.47–15 of this subchapter.

(b) Installations contracted for on or after July 1, 1935, but prior to November 19, 1952, shall meet the following requirements:

(1) Existing arrangements, materials and facilities previously approved will be considered satisfactory so long as they meet the minimum requirements of this paragraph and they are maintained in good condition to the satisfaction of the Officer in Charge, Marine Inspection. Minor repairs, and alterations may be made to the same standard as the original installation.

(2) Steam shall be available from the main or auxiliary boilers to provide at least one pound of steam per hour for each 50 cubic feet of gross volume of the largest compartment protected. Where reasonable and practicable, the steam pressure shall be at least 100 p.s.i.

(3) The piping system shall meet the general requirements of paragraphs (c)(5) through (12) of this section insofar as is reasonable and practicable.

(4) The minimum size of distribution piping and the number of branches to the various spaces shall be as given in table 76.13–90(b)(4) or by the following formula:

$$D = \sqrt{C/30,000} \quad (1)$$

where:

D = Required diameter of pipe in inches.

C = Volume of compartment in cubic feet.

TABLE 76.13–90(b)(4)

Volume of compartment in cubic feet		Number of branches to compartment	Pipe size of each branch, inches
Over	Not over		
.....	30,000	1	1
30,000	46,000	1	1¼
46,000	67,000	1	1½
67,000	94,000	1¾
94,000	135,000	2	1½
135,000	203,000	3	1½